

**Jharkhand State Electricity Regulatory Commission  
Ranchi**

**FORM OF PROCEEDING  
Case No. 41 of 2011**

Dhananjay Sharma ..... Petitioner  
Vrs.  
Jharkhand State Electricity Board ..... Respondent

<b>Sl.No.</b>	<b>Date of proceeding</b>	<b>Proceedings of the Commission with signature</b>	<b>Office action taken with date</b>
1	2	3	4
08	07.04.2012	<p>Learned Lawyer Mr. Kumar Sundaram and Mr. Dharamdeo Ram, EEE, Daltonganj are present for JSEB.</p> <p>Shri Dhananjay Shukla, Bharat Swabhimaan Trust, Patanjali Yog Samiti, Palamu is present for the petitioner.</p> <p>The JSEB has informed that 39 electric poles have been sent to the village in question and other material is being organized by the G.M. Medininagar. The field officers feel that they will complete the work till May 2012.</p> <p>The petitioner points out that the consumers deposited the money long back in 2002 and till date villagers of the petitioner have not been given connections. The petitioner also pointed out that atleast one transformer of 200 KVA is needed in their villages.</p> <p>The field officers have to ensure that the load of the village is kept in mind in installing the transformer otherwise the system will not work. If there is problem of procuring 200 KVA transformers, then two transformers of 100 KVA each be ensured in that villages.</p> <p>Put up this case on 16.06.2012 at 11.30 A.M for further hearing.</p> <p>Let a copy of this order be sent to the parties accordingly.</p> <p style="text-align: right;">Sd/- Chairperson</p>	