

Jharkhand State Electricity Regulatory Commission Ranchi

FORM OF PROCEEDINGS

Case No. 12 of 2012

Tata Power Company Limited (TPCL) Petitioner

Sl.No.	Date of proceeding	Proceedings of the Commission with signature	Office action taken with date
1	2	3	4
03	18.08.2012	<p>Shri Aweek Chatterjee, Senior Manager, Regulation Eastern Region, Shri Ashok Kumar Lodh, AGM, and Shubhayu Sanyal, Executive are present for the petitioner.</p> <p>The petitioner is heard.</p> <p>During the course of hearing, it transpired that the petitioner has submitted a line diagram of raw water circuit which shows one common meter for the total drawl of raw water for unit Nos. 1,2,3,4 & 5 and apportionment of drawl of raw water of each unit has been work out on the basis of gross generation of each unit. The Commission believes that it will be better if a separate water meter is installed for unit 2 & 3 to know the exact consumption of raw water.</p> <p>The petitioner agrees to examine the technical feasibility and get back to the Commission. During the course of hearing, the Commission made it clear that the Commission agrees, in principles, the expenditure incurred towards drawl of raw water for unit No. 2 & 3 and will be allowed subject to the firming of figures of drawl of raw water.</p> <p>Put up the case on 22.09.2012 at 11.30 AM.</p> <p>Let a copy of this order be sent to the Petitioner Tata Power Company Limited (TPCL).</p> <p style="text-align: center;">Sd/- Member</p> <p style="text-align: center;">Sd/- Chairperson</p>	