

Jharkhand State Electricity Regulatory Commission Ranchi

Form of Proceedings

Case No. 19 of 2018

M/s Adani Power Jharkhand Limited Petitioner

Versus

Jharkhand Bijli Vitran Nigam Limited & anr..... Respondent

For the petitioner : Mr N.K. Pasari, Mr. Vikasha Gupta and
Mr. Sumit Prakash, Advocates.

For the Respondents : Mr Amitabh and Mr. Amit Sinha, Advocates

Sl.No	Date of Proceeding	Proceeding of the Commission with signature	Office action taken with date
1	2	3	4
07	20.11.2018	<p>Heard the learned counsels for the petitioner and the respondents.</p> <p>The petitioner has filed a petition for approval for grant of electrical connection at 132 KV for load of 2 MVA in the beginning upto 40 MW (peak load) – July 2021 to Dec 2021 under clause 4.7 of Electricity Supply Code Regulations. The petitioner has submitted that the load requirement over the period will be as follows:</p> <ul style="list-style-type: none">• 2000 KVA – October 2018 to July 2019• 3000 KVA – August 2019 to July 2020• 5000 KVA – August 2020 to December 2020• 7500 KVA – January 2021 to June 2021• Further requirement for commissioning power upto 40 MW (peak load) – July 2021 to December 2021. <p>The respondent-JBVNL through its affidavit and also through the letter No. 857 dated 13.7.2018 enclosed in the petition of the petitioner and during the hearing has requested the Commission to grant the approval. The respondent-JUSNL</p>	

has also filed affidavit supporting the request of the petitioner and JBVNL, and also mentioned that this issue of LILO was discussed in the Eastern Region Power Committee (ERPC), Kolkata. They have further submitted that the ERPC has no objections to grant of proposed connection.

In the circumstances, the Commission grants approval with the following conditions:-

1. The entire related infrastructure will be developed by the petitioner at its own cost and will be transferred to the licensee without any cost.
2. The cost of infrastructure will not be reimbursed by the licensee, nor it will be adjusted in the tariff bill any time.
3. Infrastructure including Sub-station premises will be available to the licensees to supply electricity to any other consumer by augmenting the facility.
4. As submitted by JBVNL in his affidavit, the connection will be treated as temporary and tariff will be charged accordingly.
5. All the conditions mentioned by the ERPC will be followed.
6. Proper arrangement of metering, billing and network/ system protection would be ensured. Licensees have to ensure that supply of electricity to other consumers is not adversely affected.

The petition of the petitioner is disposed of accordingly.

Sd/-
Member (E)

Sd/-
Chairperson