

**Jharkhand State Electricity Regulatory Commission
Ranchi**

Form of Proceedings

Case No. 18 of 2019

M/s Shree Cement Limited Petitioner
Versus

Jharkhand Bijli Vitran Nigam Limited (JBVNL) & Ors Respondents

**CORAM: HON'BLE SHRI R.N. SINGH, MEMBER (ENGINEERING)
HON'BLE SHRI P.K. SINGH, MEMBER (LEGAL)**

For the Petitioner : Mr. M.S. Mittal, Sr. Advocate and Mr. Saket Upadhyay
Advocates and Mr. Amerjit Singh-Representative
For the Respondent : Mr. Navin Kumar, Mr. Amitabh, Mr. Dheeraj Kumar
Advocates and Mr. Sailesh -Representative of JUSNL

Sl.No	Date of Proceeding	Proceeding of the Commission with signature	Office action taken with date
1	2	3	4
10	28.07.2020	<p>Case called out.</p> <p>Learned Counsels of both the parties appeared for virtual hearing.</p> <p>Learned Counsel for the Petitioner submitted supplementary affidavit in this case through email along with attachments.</p> <p>Learned Counsel for the Respondent JUSNL filed its reply in this case through email today itself and submitted that the connectivity of Roof Top Solar PV is allowed up to 33 KV which is covered under the purview of Distribution Company and JUSNL grid system is operating at 132 KV and above voltage levels. It is submitted that the prayer of the petitioner is not covered within the purview of the existing regulations. A copy- paste similar affidavit has been filed by The SLDC and by the same person.</p>	

We have heard the matter in length. Learned Counsel for the petitioner has vehemently argued that the petitioner has almost removed the deficiencies pointed out by the technical team constituted by the JBVNL. However it is conceded that some of the deficiencies pointed out will be removed within a fortnight.

We have considered the affidavits filed by the JUSNL and SLDC as well as the counter filed by the JBVNL. We have reiterated in all the previous orders and directed the learned counsels as well the officials of the respondent in clear terms to state on affidavit regarding *”safety aspect of the electric system including ie electrical protection of the system including transmission network, since JSUNL and SLDC are necessary stakeholder for protection of the system especially transmission network, if the prayer in the petition is accepted”*. **We find that the directions of the commission is not being properly appreciated or intentionally defied. All the three respondents are directed to file fresh affidavit with regard to the same before the fixed date.**

Put up on 19th August, 2020 at 2.30 PM for hearing.

Sd/-
Member (L)

Sd/-
Member (E)