

Jharkhand State Electricity Regulatory Commission Ranchi

Form of Proceedings

Case No. 18 of 2019

M/s Shree Cement Limited Petitioner
Versus

Jharkhand Bijli Vitran Nigam Limited (JBVNL)..... Respondent

**CORAM: HON'BLE SHRI R.N.SINGH, MEMBER (ENGINEERING)
HON'BLE SHRI P.K.SINGH, MEMBER (LEGAL)**

For the Petitioner : Mr. M.S. Mittal, Sr. Advocate and Mr. Saket Upadhyay
Advocates

For the Respondent : Mr. Mithilesh Kumar Pandey, Advocate (JUSNL)

Sl.No	Date of Proceeding	Proceeding of the Commission with signature	Office action taken with date
1	2	3	4
14	16.09.2020	<p>Case called out. Learned Counsel for the parties appeared for virtual hearing. Learned Counsel for the Petitioner filed affidavit after serving copy to the Respondents.</p> <p>The Respondent-JUSNL filed supplementary affidavit in this case and submitted that Grid Substation of JUSNL has not been connected to Solar PV Generators as yet and there are challenges associated with solar PV integration to Grid like harmonics, DC injection, flickering, dynamically varying reactive power support etc. and in order to address these issues properly, they need to hire expert/consultants for technical study, for which cost shall be borne by the petitioner.</p> <p>The Petitioner submitted that a team comprising of representatives of the petitioner and the Respondent-JUSNL may visit their Solar Plant to satisfy with regard to safety and protection aspects and submit a report before this Commission. Learned Counsel further submitted that with the above said team, if</p>	

required an independent third party/expert may accompany the team for which, the cost of third party/expert would be borne by the petitioner.

The Respondent-JUSNL prayed for two weeks time to suggest the name of expert/consultant for technical study on protection system along with cost of additional protective gear equipment required for safe and reliable operation of JUSNL transmission network system.

Prayer is allowed.

Since the petitioner is ready to bear the cost of Technical Study emphasized by the Respondent-JUSNL, the Respondent-JUSNL is directed to get the Technical Study regarding Transmission System Protection etc. done on or before the next date of hearing.

Further, the Petitioner is also directed to nominate one competent Representative of the Shree Cement within two working days of this order with intimation to this Commission and the Respondent JUSNL to furnish Technical input required in the above said study.

Any adjournment for the same will not be allowed.

Put up on 06.10.2020 at 2.30 pm for hearing

Sd/-
Member (L)

Sd/-
Member (E)