

**Jharkhand State Electricity Regulatory Commission
Ranchi**

Form of Proceedings

Case No. 28 of 2020

Sashanka Agrotech Pvt. Ltd. Vrs. Petitioner

Jharkhand Bijli Vitran Nigam Limited and Ors. Respondents

**CORAM: HON'BLE SHRI R.N.SINGH, MEMBER (ENGINEERING)
HON'BLE SHRI P.K.SINGH, MEMBER (LEGAL)**

For the Petitioner : Mr Navin Kumar, Advocate

For the Respondent : Mr. Manoj Kumar, Advocate

Sl.No	Date of Proceeding	Proceeding of the Commission with signature	Office action taken with date
1	2	3	4
03	06.01.2021	<p>Case called out.</p> <p>Learned Counsels for the parties appeared for virtual hearing. A counter-affidavit has been filed by the respondent.</p> <p>This case has been brought by the petitioner under Clause 4.7 of JSERC (Electricity Supply Code) Regulations, 2015 seeking approval of the Commission for taking new HT connection at supply voltage of 33KV having contract demand of 700KVA .</p> <p>A counter-affidavit has been filed by the respondent.EE of The division Sri Rajesh Kumar Mandal appeared for the respondent through virtual mode. He has stated that power supply to the petitioner is feasible from existing 33KV line through 33 KV XLPE UG cable by way of tapping, as the location is nearer. It is further stated that proper energy accounting check may also be provided at the tapping location. It is further submitted that the approval may be given with a rider that the petitioner shall not claim for high voltage rebate.</p> <p>Heard both the parties at length.</p> <p>Order reserved.</p> <p style="text-align: center;">Sd/- Member (L)</p>	<p style="text-align: center;">Sd/- Member (E)</p>