

**Jharkhand State Electricity Regulatory Commission
Ranchi**

**Form of Proceedings
Case No. 10 of 2023**

M/s Dilip Buildcon Limited Petitioner

Versus

Jharkhand Bijli Vitran Nigam Limited & Ors..... Respondents

**CORAM: HON'BLE MR. AMITAV KUMAR GUPTA, CHAIRPERSON
HON'BLE MR. MAHENDRA PRASAD, MEMBER (LAW)
HON'BLE MR. ATUL KUMAR, MEMBER (TECH)**

For the Petitioner : Mr. Dhananjay Kumar Pathak, Advocate

For the Respondent : Mr. Srijan, Advocate

Sl.No	Date of Proceeding	Proceeding of the Commission with signature	Office action taken with date
1	2	3	4
3.	11.07.2023	<p>Case called out.</p> <p>Learned counsel for the petitioner has drawn the attention of Commission to Annexures 7 & 7/1, i.e. the report submitted by the AEE/S/Godda and EEE/S/Godda, wherein the concerned officials have recommended for sanctioning of power supply at 33KV voltage level.</p> <p>Learned counsel appearing on behalf of the respondent has filed the counter affidavit and submitted that as per Annexure – A, the letter issued by the Electrical Superintending Engineer, Deoghar for connection at higher voltage of 33 KV, the applicant must apply for a contract demand exceeding 1500 KVA, whereas the petitioner has a contract demand of 1000 KVA. Thus the supply of 33 KV on the contract demand of 1000 KVA will be in contravention of clause 4.3 of JSERC (Supply Code) Regulation, 2015.</p>	

At this stage, learned counsel for the petitioner submitted the company has installed the plant for fulfilling the need of NHAI however due to interrupted supply at 11 KV there is likelihood of hampering in the smooth functioning of the plant, therefore the petitioner has prayed for supply of power at 33 KV and they are willing to the voltage rebate for 33 KV.

Learned counsel of respondent has prayed for time to seek necessary instructions in view of the submission of the petitioner.

On the request of learned counsel for the respondent time is granted with a direction that the concerned Electrical Superintending Engineer shall submit the interruption report of 11 KV connectivity and the report regarding connectivity at 33KV voltage level pertaining to the petitioner.

Office to list this case on 01.08.2023 at 2.00 PM.

Sd/-
Member (T)

Sd/-
Member (L)

Sd/-
Chairperson