

**Jharkhand State Electricity Regulatory Commission
Ranchi**

Form of Proceedings

Case No. 23 of 2018

M/s Shree Jharkhand Cement Plant Petitioner

Versus

Jharkhand Bijli Vitran Nigam Limited & anr..... Respondent

For the petitioner : Mr M.S Mittal, Sr. Advocate, Mr. N.K. Pasari,
Ms Vishakha Gupta and Ms S. Jalan, Advocates.

For the Respondents : Mr Amitabh, Advocate

| Sl.No | Date of Proceeding | Proceeding of the Commission with signature | Office action taken with date |
|-------|--------------------|--|-------------------------------|
| 1 | 2 | 3 | 4 |
| 05 | 05.12.2018 | <p>Heard the learned counsels for the petitioner and the respondents.</p> <p>The petitioner has filed this petition for grant of approval for availing power supply at a Contract Demand of 14 MVA on 132 KV voltage pressure in terms of the provision contained in Clause 4.7 of JSERC (Electricity Supply Code) Regulations 2015. The petitioner is intending to draw power from Rajkharsawan Grid Sub-Station which is the nearest sub-station from the petitioner's premises and will be without any obstacle of any nature, much less any technical disruption of the supply of electricity. Therefore, the petitioner has stated that it would be appropriate for the petitioner to say with all bonafide that the supply of electricity to petitioner's premises be approved from Rajkharsawan Grid Sub-station at 132 Kv voltage pressure.</p> <p>In the instant petition the petitioner has stated that on</p> | |

1.11.2017 Memorandum of Understanding was entered into between the petitioner and the Government of Jharkhand for setting up 4 MTPA Cement Grinding Unit in two phases and also for setting up a 20 MW Captive Power Plant within the State of Jharkhand with the proposed investment of Rs.630 crores in 24 months in phased manner. It has further been stated that initially 2 MTPA Cement Grinding Unit has already been established and various modalities required has already been completed.

The petitioner has also stated that since the unit proposed to be established in phase-wise manner and the motors installed by the petitioner needs voltage pressure and cannot afford to be tripped time and again because of there being multiple connection at 33 KV supply. Further, it has been stated that within a period of two years, the petitioner has to start another 2 MTPA Cement Grinding Unit, the requirement of Contract would be higher and the cost would be huge because at the end of the day the petitioner would have to avail power supply at voltage level of 132 KV only.

The respondent-JBVNL through its affidavit and during the hearing has requested the Commission to grant the approval. The respondent-JUSNL has also filed affidavit supporting the request of the petitioner and JBVNL.

In the circumstances, the Commission grants approval with the following conditions:-

1. The related infrastructure will be developed by the petitioner at its own cost.
2. The cost of infrastructure will not be reimbursed by the licensee, nor it will be adjusted in the tariff bill any time.

3. Proper arrangement of metering, billing and network/
system protection would be ensured. Licensees have to
ensure that supply of electricity to other consumers is
not adversely affected.

The petition of the petitioner is disposed of accordingly.

Sd/-
Member (E)

Sd/-
Chairperson