

**IN THE JHARKHAND STATE ELECTRICITY REGULATORY COMMISSION
AT RANCHI**

Case No. 20 of 2020

M/s R. P. Cylinders Pvt. Ltd. Petitioner

Versus

Jharkhand Bijli Vitran Nigam Limited and Ors. Respondent

**CORAM: HON'BLE MR. R.N. SINGH, MEMBER (ENGINEERING)
HON'BLE MR. P.K. SINGH, MEMBER (LEGAL)**

For the Petitioner : Mr. Dhananjay Kumar Pathak, Advocate
For the Respondent : Mr. Manoj Kumar, Advocate

Date -9th Januray, 2021

1. The Petitioner – R.P. Cylinders Pvt. Ltd. has submitted an affidavited petition purported to be filed under clause 4.7 of JSERC (Electricity Supply Code) Regulations, 2015 for grant of approval for supply of 500 KVA at 33 KV voltage supply.
2. The Petitioner in its petition has prayed for the following reliefs:-
 - (i) That by way of instant application the petitioner prays for grant of approval from this Hon'ble Commission for getting supply of power at 33 KV with a contact demand of 500 KVA in terms of the provisions contained under clause 4.7 of the Electricity Supply Code Regulation issued by this Hon'ble Commission.

AND/OR

- (ii) The petitioner prays for issuance of such other order or orders as Your Honour may deem fit and proper in the interest of justice.

The factual matrix of the case may be appreciated in the following manner;

3. It is submitted that the petitioner is registered is a LPG Cylinder manufacturing company and gets its connection energized with a contract demand of 500 KVA at 11 KV, however due to frequent tripping/power cut, the petitioner got its load reduced from 500 KVA to 250 KVA in the month of June, 2020.
4. It is submitted that in the production of LPG cylinders due to tripping of power, the continuity of manufacturing process gets disrupted leading to chance of gas leakage through the cylinder which are manufactured through disrupted process. Hence, considering the life & safety and the

nature of the product, the petitioner requires Uninterrupted power supply at 33 KV voltage supply only.

5. It is submitted that the petitioner is ready to bear all the infrastructural expenses for 33 KV voltage supply.
6. It is submitted by the learned counsel for the petitioner that the Commission may grant conditional approval that the Respondent shall give 33 KV supply only after enhancement of load from 250 to 500 KVA.
7. It is submitted that the Respondent – JBVNL has no objection in approval of the Commission for 33 KV voltage supply.
8. It is agreed that the petitioner shall not claim for high voltage rebate against availing supply at higher voltage level.

In the result, it is ordered as;

ORDER

9. The Prayers of the petitioners are allowed. The Respondent may allow new connection at voltage supply of 33KV subject to enhancement of Contract demand from 250 KVA to 500 KVA and after ensuring proper arrangement of metering, billing and network system protection.
10. It is hereby clarified that the petitioner will not avail voltage rebate corresponding to 33KV voltage supply until its contract demand reaches to the category of 33KV, as per the JSERC (Electricity Supply Code) Regulations, 2015.
11. Accordingly, the Petition of the petitioner is disposed of in terms of the above order.

(P.K.Singh)
Member (Legal)

(R.N. Singh)
Member (Engg)